



**NOTES**

1. The meter pedestal shall be installed by the customer before the service lateral is installed.
2. Meter must be readily accessible with no obstructions. a clear work area with an 18" clearance on all sides and a 36" clearance in front of meter base to a height of 84" is required.
3. Customer is solely responsible for identifying or locating all below grade facilities near the excavation of the service cable including but not limited to electric conductors, communication lines, gas lines, water lines, sewer lines, drain fields, septic tanks, etc.
4. Customer will be required to provide a clear path, 20 feet in width, from the power source to the meter base to allow Cooperative to trench and install service cable.

1	TITLE BLOCK CHANGE	01-03-12	DATE: 01-03-12
			DRAWN BY: J. CHOI
			APPD BY: K. MARA
NO.	REVISION	DATE	

UNDERGROUND SERVICE FOR  
 TEMPORARY CONSTRUCTION SERVICE/  
 PERMANENT UNDERGROUND SERVICE  
 DEEP EAST TEXAS ELECTRIC COOP.  
 HI-LINE ENGINEERING      MARIETTA, GEORGIA